



Subject: Water Quality Testing results for Albert R Sabin Elementary Magnet School

Dear Chief Nicole Milberg and Principal Gwen Ann Kasper-Couty,

At CPS, our top priority is ensuring the health and safety of our students and staff, and we take a proactive approach to maintaining safe drinking water in our schools. Lead can be found in pipes, faucets, and interior plumbing fixtures and materials and we believe routine water testing is an important and necessary action to ensure the safety of our drinking water.

Per the Environmental Protection Agency's (EPA) guidance on lead in drinking water, lead concentrations in drinking water should not exceed 15 parts per billion (ppb). Per the Illinois Department of Public Health (IDPH) guidance, lead concentrations in drinking water shall not exceed 5 ppb. Any fixture that produces a reading above 5 ppb will be removed from service.

On July 29, 2022, we tested 1 water source(s) at Albert R Sabin Elementary Magnet School, and all samples were below the IDPH's limit of 5 ppb for lead in drinking water. The following are the results:

- 1 location(s) had water samples below 5.00 ppb
- 0 location(s) had water samples at or between 5.00 ppb and 15 ppb
- 0 location(s) had water samples above 15.00 ppb

To ensure you have the necessary support to share this news with your school community, attached is the following:

- A note for parents from Richard Schleyer, Director of Environmental Health and Safety;
- For parents concerned about testing water levels at home, they can request a water test kit from the Department of Water Management: www.chicagowaterquality.org;
- A FAQ about CPS' lead testing procedures that you can use to educate your staff and LSC.

In addition, test results will be available on cps.edu/waterqualitytesting. This link will be referenced in the parent letter, and you may also want to consider placing it on your school's homepage to answer any questions your community may have.

If you have any questions related to the lead in the drinking water testing, please contact environmental@cps.edu.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director of Environmental Health and Safety
Chicago Public Schools



Subject, if electronic: Water Quality Testing Results for Albert R Sabin Elementary Magnet School

Dear Albert R Sabin Elementary Magnet School Parents and Families,

Our top priority is ensuring the health and safety of our students and staff, and we take a proactive approach to maintaining safe drinking water in our schools. Lead can be found in pipes, faucets, and interior plumbing fixtures and materials and we believe routine water testing is an important and necessary action to ensure the safety of our drinking water.

On July 29, 2022, we tested water samples from 1 source(s) in your school. All samples tested below 5 ppb.

The full results of your school's water samples can be found online at cps.edu/waterqualitytesting.

Federal guidance indicates that children under the age of six are at the highest risk for harmful lead exposure, and they can be exposed to lead from a variety of sources. The most common source of lead exposure is lead-based paint or dust, but other sources include water, soil, and even some consumer products. If you are concerned about your child's possible lead exposure risks, the Chicago Department of Public Health (CDPH) recommends contacting your pediatrician to discuss having your child tested.

If you have any other health-related questions or concerns, CDPH's lead hotline (312-747-5323) can help you determine whether your child should be tested for lead. Additional information is also available at the Centers for Disease Control's website at www.cdc.gov/lead.

Your child's health and safety is of utmost important to us. We will continue to keep you and your family informed throughout this process.

Sincerely,

A handwritten signature in black ink that reads "Richard J. Schleyer".

Richard J. Schleyer
Director of Environmental Health and Safety
Chicago Public Schools



Asunto, si es electrónico: Resultados de las Pruebas de la Calidad del Agua para Albert R Sabin Elementary Magnet School

Estimados padres y familias de Albert R Sabin Elementary Magnet School

Nuestra prioridad primordial es garantizar la salud y la seguridad de nuestros estudiantes y personal, y adoptamos un enfoque proactivo para mantener la seguridad del agua potable en nuestras escuelas. El plomo se puede encontrar en las tuberías, los grifos y los artefactos y materiales interiores de plomería y creemos que hacer pruebas de agua rutinariamente es una acción importante y necesaria para garantizar la seguridad de nuestra agua potable.

El 29 de julio de 2022, analizamos muestras de agua de 1 fuente(s) de agua en su escuela. Todas las muestras dieron resultados por debajo de 5 ppb.

Podrá encontrar los resultados completos de las muestras de agua de su escuela en el sitio web cps.edu/waterqualitytesting.

La guía federal indica que los niños menores de seis años posan mayor riesgo a la exposición dañina del plomo, y que pueden estar expuestos al plomo por medio de una variedad de fuentes. La fuente de exposición al plomo más común es la pintura con base de plomo o el polvo, pero otras fuentes incluyen el agua, la tierra e incluso algunos productos de consumo. Si le preocupa los posibles riesgos de exposición al plomo de su niño/niña, el Departamento de Salud Pública de Chicago (Chicago Department of Public Health – CDPH) recomienda que se ponga en contacto con su pediatra para discernir si su hijo/hija deberá tomar una prueba.

Si usted tiene cualquier otra pregunta o preocupación relacionada con la salud, la línea de ayuda para el plomo del CDPH (312-747-5323) puede ayudarle a determinar si su hijo/hija deberá tomar una prueba de plomo. En el sitio web www.cdc.gov/lead de los Centros para el Control de Enfermedades (Centers for Disease Control) hay también información adicional.

La salud y la seguridad de su niño/a es de primordial importancia para nosotros. Les mantendremos informados a usted y a su familia durante este proceso.

Sinceramente,

Richard J. Schleyer
Director de Seguridad y Salud Ambiental
Chicago Public Schools

Get the Facts: Lead

The Chicago Department of Public Health (CDPH) works to detect and address exposures to lead hazards. Through strategic inspections and abatement, as well as public education campaigns and testing, CDPH is leading efforts to permanently eliminate lead exposure to children. As a result, the number of children with elevated lead levels has declined from one in four tested in the late 1990's to less than one in 100 today. Here are some facts about lead in Chicago and tips for parents and guardians to help stop children from coming into contact with lead.

What are the health effects of lead?

When young children are exposed to lead, it can affect their growth, behavior, and development. When pregnant women are exposed to lead, it can affect their infants' brain and nervous system development.

How are most children in Chicago exposed to lead?

In Chicago, children are most likely to be exposed to lead while living or staying in older homes or apartments that have lead paint. Most homes built before 1978 (when lead paint was banned in the U.S.) have some lead paint on the inside and outside of the building. When old paint cracks and peels, it makes lead dust. Lead dust is so small you cannot see it or smell it. Children may get lead poisoning from swallowing or breathing in lead dust on their hands and toys.

What are other ways children can be exposed to lead?

Lead can also be found in soil, water, pots, containers, candy, folk medicine, cosmetics made in other countries, and some toys and toy jewelry. For up-to-date information on recalls of toys and other products that contain lead you can check <http://www.cpsc.gov/>.

What about lead in tap water?

When lead is found in household tap water, it comes from the plumbing in and near the home, not the local water supply. Water leaving the water treatment plant is free of lead. While the use of lead pipes was banned in 1986, lead can be found in older metal water taps, interior water pipes, solder connecting pipes, or pipes connecting a building to the main water pipe in the street. Lead found in tap water usually comes from the corrosion of these items. A corrosion inhibitor is added to Chicago's drinking water, which forms a coating on the inside of water service lines; however, if water is unused for long periods of time lead from plumbing or pipes can leach into the water.

Who is at greatest risk of lead poisoning in Chicago?

We worry most about young children (especially ages 0-3, but up to age 6) both because their brains are developing rapidly and because they are more likely to put their hands and objects contaminated with lead dust into their mouths. Children who live in older, poorly maintained homes or apartments or who have parents who are exposed to lead at work or through other activities are also at increased risk for lead poisoning.

How do I know if my child has lead poisoning?

A simple blood test is the only way to know if your child has lead poisoning. Most children who have lead poisoning do not look or act sick.

Should my child be tested for lead?

Yes. Because Chicago has many old homes, **every child living in Chicago** should be tested for lead through their healthcare provider's office. Children should be tested at 12, 24, and 36 months of age. Children between 3 and 6 years of age may also need to be tested. Additionally, children need to have proof of lead testing upon enrollment in day care and kindergarten.

What if my child does not have a regular healthcare provider?

If your family has a medical card as a part of the Medicaid Program, you are already assigned to a healthcare provider. If you don't know who your healthcare provider is you can call 1 (877) 912-8880. If you do not have health insurance, you can enroll your family by calling (773) 985-8055 or 1 (866) 311-1119.

I'm pregnant. Should I be tested for lead?

No, but women who are pregnant or nursing should consult with their healthcare provider if they have questions or concerns.

I am pregnant or have a young child. How do I know if my home is lead safe?

Find out when your home was built, as well as any other home where your young child spends a lot of time (like grandparents or daycare). If the housing was built before 1978, assume that the outdoor and indoor paint contain lead, unless tests show otherwise. Visit the Cook County Assessor's office at: www.cookcountyassessor.com to learn the age of your home. If you are interested in getting your home tested for lead, visit <https://data.illinois.gov/> and use the search term "lead inspector" to identify a state-licensed lead inspector. If you have concerns about lead in your tap water, call 311 or visit www.chicagowaterquality.org to request that your tap water be tested.

What can I do to protect my child from lead in soil or outside my home?

Prevent young children from playing in bare soil, which can contain lead. If possible, plant grass, cover bare soil with mulch or wood chips, or let children play in sandboxes. Remove shoes prior to entering the home.

My home was built before 1978 and I have a young child. What should I do if I see chipping/peeling paint?

Make sure your child is not around chipping or peeling paint or chewable surfaces (like windowsills). Take your child to their healthcare provider for a lead test. Until your home has been tested and safe environmental clean-up is completed, close and lock doors to affected areas, or put furniture in front of the area (do not put furniture in front of windows). Temporarily, you can also apply contact paper or duct tape to cover holes in walls or to stop children from chewing on lead-painted areas. Do NOT remodel or renovate until your home has been inspected for lead. Home repairs like sanding and scraping paint can produce dangerous lead dust. If you are interested in getting your home tested for lead, contact a state-licensed lead inspector.

What else can I do to protect my child from lead exposure inside my home?

Household dust is a major source of lead. Windowsills and window wells, in particular, can contain a lot of leaded dust. Clean your home weekly. Use a solution of water and cleaner to wet-mop floors and to wipe windowsills and other surfaces. Don't reuse cloths or sponges on dishes or counters. Don't dry-dust, sweep, or vacuum as these activities can spread lead dust. Remove shoes prior to entering the home. Wash hands and toys often with soap and water and always wash hands before eating and sleeping. When possible, windows should be shut to prevent abrasion of painted surfaces. In addition, parents who work in auto repair, construction, or plumbing, or who make stained glass or use firing ranges can carry lead dust on themselves. Shower and change clothes before interacting with young children.

How can I reduce exposure to lead in the tap water?

To reduce exposure to lead in the tap water, always use cold water from the tap for drinking, cooking, and making baby formula, as hot water is more likely to contain lead. Boiling water does not remove lead. After long periods of stagnation (6 hours or more without running water in your home or apartment), flush your water system. This can be done by running the tap for a minimum of 5 minutes, flushing the toilet, taking a shower, or doing laundry. You may consider purchasing and installing a filter that is certified to remove lead. If you have concerns about lead in your tap water, call 311 or visit www.chicagowaterquality.org to request that your tap water be tested. For more information, visit www.cdc.gov/nceh/lead/tips/water.

What if I have my water tested and it shows elevated levels of lead in my tap water?

If your water test results show lead levels about 15 parts per billion (the 'action level' set by the Environmental Protection Agency), the City's Department of Water Management (DWM) will schedule a visit to your home, accompanied by a plumber and an electrician. DWM will evaluate your home to help determine the potential source of lead and recommend a plan of action to address it.

Are there any foods that help prevent lead poisoning?

Giving your child healthy foods is important for healthy development and is also helpful for preventing lead poisoning. Foods with calcium, iron, and vitamin C can help keep lead out of the body. Calcium is in milk, yogurt, cheese, and leafy green vegetables like spinach. Iron is in red meats, beans, peanut butter, and cereals. Vitamin C is in oranges, green and red peppers, and juice. Ask your doctor if you have questions about this.

What if I receive a report that my child has a high lead level?

If your child has a blood lead level of 5 micrograms per deciliter or greater, you and your doctor will receive a report. Talk to your doctor. Your child may need to go back to get a second lead test (for example, if the first blood test was done using a finger prick, your child may need to have blood drawn from the arm). If your child is under 6 years of age and has a blood lead level of 5 micrograms per deciliter or greater, the Chicago Department of Public Health (CDPH) will contact you and will conduct a free home inspection. If you do not hear from CDPH, you or your doctor can call (312) 747-LEAD (5323).

What if my child has a high blood lead level and a home inspection finds lead paint or other problems in my home?

If lead hazards are found on inspection, you or your landlord may need to have lead abatement done. Abatement is work done to remove or cover lead paint in your home. It can include replacing windows and other components containing lead. Abatement must be done by a state-licensed lead abatement contractor. For a list of licensed lead abatement contractors, visit <https://data.illinois.gov/> and use the search term “lead contractor.”

Is there any financial assistance available to fix lead hazards in my home or apartment?

Yes. The Chicago Department of Public Health (CDPH) has a program available that can provide financial assistance to fix lead hazards to people who meet certain income requirements. Tenants or property owners can apply. For more information, please call (312) 747-LEAD (5323).

For additional information, visit: <https://www.epa.gov/lead/learn-about-lead#lower> or <http://www.cdc.gov/nceh/lead/>